


0.5 SQ MM 1PAIR OVERALL SCREENED UNARMOURED

CU/PVC/OS/PVC



Application: The unarmoured versions (Part 2 Type 1) are generally use for indoor installation and suitable for wet and damp areas. Generally used within industrial process manufacturing plants for communication, data and voice transmission signals and services, also used for the interconnection of electrical equipment and instruments, typically in chemical or petrochemical industry
Conductor: Circular stranded copper wire to IEC60228, class 2
Stranding: 0.5mmsq =16/0.2 mm

Size	1 X 2X 0.5MM ² CU/PVC/OS/PVC	Type: Instrumentation cable	
		Standard : BS 5308-1 &2 EN 60332-1,60228	
Code: 1*2*0.5		METSEC CABLES LTD	
Sr.	Description	Thickness	Approx. Diameter
		mm	mm
	Copper size/strands		0.2/16
	Core diameter		2.10
	Insulation thickness	0.60	
	Polyester clear tape	0.05*20	
	Drain wire (Bare tinned copper)		0.5/7
	Overall aluminium foil size	0.05*20	
	Sheath thickness	0.80	



Metsec Cables Limited | P.O Box 75963-00200 | City Square, Nairobi Kenya |



TECHNICAL SPECIFICATION

DESC	RIPTION	Units	Particulars offered
Volta	ge rating	Volts	300/500
Mate	rial of conductor	Bunched Copper	Bunched Copper
Cores	s copper size	No/mm	16/0.2
Insula	ation material		PVC Compound
Insula	ation thickness	mm	0.60
Cores	diameter	mm	-
Cores	identification Colour codes		Black Blue
Cond	uctor Resistance at 20°c	Ω/Km	12.3
Num	ber of Pair	No.	1 Pair
Polye	ster clear tape	mm	0.05*20
Drain	wire (tinned copper)	No/mm	7/0.5
Alum	inium foil	mm	0.05*20
Inner	sheath bedding material		PVC Compound
Sheat	th thickness	mm	0.80
Sheat	thing material		PVC Compound
Outer	r sheath colour		Grey
Appro	oximately Overall Diameter	mm	6.00
Appro	oximately cable weight	Kg/km	34.1
Stand	lard cable length	М	1000 ± 5 %
Mark	ing	Printed	AS PER CUSTOMER'S REQUEST
Packi	ng details		Rewinded in wooden drum to protect the cable from any mechanical damage

All of the above information, including drawings, illustrations and graphic designs, reflects our present understanding and is to the best of our knowledge and belief correct reliable. Users, however, should independently evaluate the suitability of each product for the desired application. Under no circumstances does this constitute an assurance any particular quality or performance. Such an assurance is only provided in the context of our product specifications or explicit contractual arrangements. Our liability for products set forth our standard terms and conditions of sale



Metsec Cables Limited | P.O Box 75963-00200 |City Square, Nairobi Kenya|